## **Certification Boulevard**



### Test Your Knowledge of Advanced Treatment Topics Answer Key

- 1. Which chemical can be used as a food source to enhance denitrification in the activated sludge process?
  - a. Lime
  - b. <u>Methanol</u>
  - c. Ferric Chloride
  - d. Aluminum Sulfate
- 2. Given the following Ortho P (OP) data for inlet and outlet of a BNR fermentation tank, does this appear to be a problem?
  - Fermentation Inlet Ortho P is 8.5 mg/L
  - Fermentation Outlet Ortho P is 4.2 mg/L

a. No, the Ortho P removal is acceptable for this zone

- b. Yes, the fermentation outlet OP should be 2 to 3 times the concentration of the inlet
- c. The fermentation tank is designed to uptake and remove phosphorus in this zone d. Both "a & c"  $\,$

This condition could indicate that oxidation has taken place in the fermentation zone (meaning, oxygen is present in some form). Typically, that is not a good sign when trying to promote maximum biological phosphorus removal.

3. Given the following data, what is the solids loading rate on the secondary clarifiers?

- Plant Influent Flow is 5.25 mgd
- The RAS Rate is 95% of Q
- There are two (2) 100 ft Diameter Secondary Clarifiers
- The Aeration MLSS is 2,750 mg/L
- a. 11.8 lbs/day/ft<sup>2</sup>
- b. 8.6 lbs/day/ $ft^2$
- c. 13.9 lbs/day/ $ft^2$
- d. <u>15.0 lbs/day/ft<sup>2</sup></u>

#### Formula

<u>Total lbs/day Entering the Secondary Clarifiers = 234,854 lbs/day</u> = 14.96 lbs/day/ft<sup>2</sup> Total Clarifiers Surface Area = 15,700 ft<sup>2</sup>

Total lbs/day Entering the Secondary Clarifiers = (5.25 mgd + 4.99 mgd) x 2,750 mg/L x 8.34 lbs/gal = 234,854 lbs/day

Total Clarifiers Surface Area =  $3.14 \times (50 \text{ ft} \times 50 \text{ ft}) \times 2 \text{ Clarifiers} = 15,700 \text{ ft}^2$ 

- 4. Given the following data, and using the data provided in question 3, what is the F/M ratio of this activated sludge process?
  - Influent CBOD<sub>5</sub> is 213 mg/L
  - Primary Clarifier Removes 26% of the Influent CBOD<sub>5</sub>
  - MLVSS is 77% of MLSS
  - Two (2) Aeration Tanks Each 155 Feet Long, 35 Feet Wide and 15 Feet Deep
  - a. <u>0.32</u>
  - b. 0.23
  - c. 0.64
  - d. 0.11

#### Formula

Lbs/day CBOD<sub>5</sub> Entering Aeration = (213 mg/L x .74) x 5.25 mgd x 8.34 lbs/gal = 6,901 lbs/day CBOD<sub>5</sub>

# Lbs MLVSS in Aeration = ((155 ft x 35 ft x 15 ft) x 7.48 gal/ft<sup>3</sup> x 2 tanks /1,000,000) x (2,750 mg/L x .77) x 8.34 lbs/gal = 21,499 lbs MLVSS

- 5. What adjustment should be made if solids are rising in the secondary clarifier accompanied by large, smelly gas bubbles, but the RAS rate seems adequate?
  - a. Increase aeration D.O.
  - b. Decrease the RAS rate
  - c. Decrease the WAS rate
  - d. Decrease aeration D.O.

#### This septic condition requires an increased aerobic environment in the MLSS.

- 6. Given the following data, what is the percent removal of CBOD<sub>5</sub> through the activated sludge process?
  - Plant Influent Flow Rate is 256 gpm
  - Influent CBOD<sub>5</sub> is 197 mg/L
  - Primary Effluent CBOD<sub>5</sub> is 139 mg/L
  - Secondary Effluent CBOD<sub>5</sub> is 3.7 mg/L

a. 98.1%

- b. 98.6%
- c. 97.0%
- d. <u>97.3%</u>

Formula

Aeration Inlet CBOD5, mg/L - Secondary Effluent CBOD5, mg/L = 135.3 mg/L x 100 = 97.3%Aeration Inlet CBOD5, mg/L= 139 mg/L

Aeration Inlet CBOD<sub>5</sub>, = 139 mg/L Secondary Effluent CBOD<sub>5</sub>, = 3.7 mg/L

7. What type of solids cannot be removed on a filter after thoroughly being mixed in liquid?

a. Settleableb. <u>Dissolved</u>c. Colloidald. Inert

8. Is an extended aeration process typically overloaded or underloaded by design?

a. Overloadedb. <u>Underloaded</u>c. Low MLSSd. High F/M Ratio

Aeration loading refers to the CBOD5 entering the system. The extended aeration process typically has a low F/M ratio.

- 9. Given the following data, calculate the RR?
  - 27.6 mg/L/hr OUR
  - 2,221 mg/L MLVSS

a. 80.5 mg/hr/gm b. 8.7 mg/hr/gm c. <u>12.4 mg/hr/gm</u>

d. 61.3 mg/hr/gm

#### Formula

 $\frac{OUR, mg/L/hr}{MLVSS, gm/L} = 27.6 mg/L/hr}{2.221 gm/L} = 12.4 mg/hr/gm$ 

*OUR, mg/L/hr = 27.6 MLVSS, gm/L = 2,221 mg/L / 1,000 mg per gm = 2.221 gm/L* 

10. What is a typical RAS to Q ratio for a conventional activated sludge process?

a. 10% to 25%
b. <u>20% to 50%</u>
c. 1% to 2%
d. 75% to 100%

Please forward your comments and sample questions for publication to:

Roy Pelletier, Assistant Bureau Chief City of Orlando Public Works Department Wastewater Bureau 5100 L.B. McLeod Road Orlando, Florida 32811