



Certification Boulevard

Test Your Knowledge of Residuals Management

- Given the following data, what is the Specific Oxygen Utilization Rate (SOUR) in an aerobic digester?
 - OUR test starting D.O. is 6.8 mg/L
 - OUR test ending D.O. is 3.5 mg/L
 - OUR test time is 10 minutes
 - Digested sludge total solids concentration is 1.2%
 - 2.1 mg/hr/gm TS
 - 1.1 mg/hr/gm TS
 - 1.65 mg/hr/gm TS
 - 10.9 mg/hr/gm TS
- Based on Question No.1, does this aerobic digester meet EPA's vector attraction reduction regulation for Class B residuals?
 - Yes
 - No
 - Not enough data to answer this question
- Given the following data, what is the percent volatile solids reduction in an anaerobic digester using the Approximate Mass Balance (AMB) formula?
 - Feed Sludge Total Solids = 3.4%
 - Feed Sludge Volatile Solids = 2.7%
 - Feed Sludge Daily Flow = 0.09 mgd
 - Digested Sludge Out Total Solids = 2.4%
 - Digested Sludge Out Volatile Solids = 1.5%
 - Digested Sludge Out Flow = 0.09 mgd
 - 40.1%
 - 37.0%
 - 34.5%
 - 44.4%
- What happens to the pH in an aerobic digester when carbon dioxide is stripped out of the sludge?
 - The pH decreases
 - The pH increases
 - Carbon dioxide does not affect pH
 - Alkalinity is increased

5. What are the requirements for lime stabilization to accomplish Class B stabilization standards?
- Raise the sludge pH to no greater than 11.0
 - Raise the sludge pH to at least 12 for the first 2 hours, and then maintain at least 12.5 for the next 24 hours
 - Raise the sludge pH to 10.0 to 10.5 for 30 minutes
 - Raise the sludge pH to at least 12 for the first 2 hours, and then maintain at least 11.5 for the next 22 hours
6. Given the following data, what is the volatile solids loading rate in an anaerobic digester?
- Digester tank diameter is 75 feet
 - Digester side water depth is 24 feet to overflow
 - Volume in cone is 35,000 gallons
 - Digester sludge feed rate is 125 gpm for 8 hrs/day
 - Sludge feed total solids concentration is 3.2%
 - Sludge feed volatile content is 81%
- 0.12 lbs per day VS per ft³
 - 0.34 lbs per day VS per ft³
 - 0.15 lbs per day VS per ft³
 - 1.5 lbs per day VS per ft³
7. Which is the EPA rule that provides rules and regulation for the disposal of wastewater residuals?
- 305 rule
 - 640 rule
 - 736 rule
 - 503 rule
8. Given the following data, what is the annual budget for lime in a lime stabilization process?
- Lime dose rate is 5.5% per wet ton of sludge
 - Sludge wet weight is 28,690 lbs/day
 - Lime cost is \$120.00 per ton delivered
 - Sludge is processed 7 days per week
- \$36,145
 - \$14,345
 - \$34,557
 - \$28,274
9. What is one of the alternate methods for vector attraction reduction for an anaerobic digestion process if the volatile solids reduction does not meet the required number?
- Chlorine residual
 - SOUR
 - Extended 40-day bench test
 - Ammonia-nitrogen

e. None of the above

10. What is the fecal coliform limit to meet standards for Class B biosolids?

- a. 1,000 #/gram TS
- b. 10,000 #/gram TS
- c. 1,000,000 #/gram TS
- d. 2,000,000 #/gram TS