



Certification Boulevard

Test Your Knowledge of Water Supply and Other Miscellaneous Topics – Answer Key

1. A potable water flow meter reads 175 gpm for 8.5 hrs/day, 95 gpm for 6.5 hrs/day and 48 gpm for the remainder of the 24-hour day. What is the total daily flow in mgd?
 - a. 0.64740 mgd
 - b. 0.09576 mgd
 - c. **0.1522 mgd**
 - d. 0.1870 mgd

$$(175 \text{ gpm} \times 8.5 \text{ hrs/day} \times 60 \text{ mins/hr}) + (95 \text{ gpm} \times 6.5 \text{ hrs/day} \times 60 \text{ mins/day}) + (48 \text{ gpm} \times 9 \text{ hrs/day} \times 60 \text{ mins/hr})$$
$$89,250 \text{ gpd} + 37,050 \text{ gpd} + 25,920 = 152,220 \text{ gpd} \div 1,000,000 = 0.1522 \text{ mgd}$$

2. Given the following data, what is the annual budget for sodium hypochlorite at this package water plant?
 - Finished water flow is 200,000 gpd
 - Chlorine dosage is 20 mg/L
 - Sodium Hypochlorite solution strength is 11.25%
 - Bulk density of solution is 9.7 lbs/gal
 - Cost per bulk liquid gallon is \$0.38
 - a. \$22,655 per year
 - b. **\$4,240 per year**
 - c. \$26,224 per year
 - d. \$3,396 per year

$$\text{Lbs/day of solution} = \text{lbs/day chlorine used} \div \text{solution strength}$$

$$\text{Gals/day solution} = \text{lbs/day solution} \div \text{density of solution}$$

$$(0.2 \text{ mgd} \times 20 \text{ mg/L} \times 8.34 \text{ lbs/gal}) \div 0.1125 = 296.5 = \text{lbs/day solution}$$
$$296.5 \text{ lbs/day solution} \div 9.7 \text{ lbs/gal} = 30.57 \text{ gpd} \times 365 \text{ days/year} = 11,158 \text{ gal/year}$$
$$11,158 \text{ gal/year} \times \$0.38 \text{ per gallon} = \$4,240 \text{ per year}$$

3. What is the velocity in cubic feet per minute (cfm) of a 1 mgd stream of water?
 - a. 1.55 cfm
 - b. 8.34 cfm
 - c. 7.48 cfm
 - d. **92.84 cfm**

$$1,000,000 \text{ gpd} \text{ divided by } 1,440 \text{ mins/day} \text{ divided by } 7.48 \text{ gal/cu.ft.} = 92.84 \text{ cfm/mgd}$$

4. Given the following data, calculate the approximate horsepower delivered by this pump:

- Flow is 700 gpm
- TDH is 85 feet
- Does not consider pump and motor efficiency

- a. **15 HP**
b. 20 HP
c. 25 HP
d. 7.5 HP

$$\begin{aligned} \text{Horsepower} &= (\text{gpm} \times \text{TDH, feet} \times 8.34 \text{ lbs/gal}) \div 33,000 \text{ foot lbs/second} \\ 700 \text{ gpm} \times 85 \text{ TDH} \times 8.34 \text{ lbs/gal} &\div 33,000 \\ &= 15.04 \text{ HP} \end{aligned}$$

5. Which repair kit is designed for use with 150-pound chlorine cylinders?

- a. **"A" kit**
b. "B" kit
c. "C" kit
d. None of the above

6. If a gallon of water weighs 8.34 lbs, and a cubic foot of water holds 7.48 gallons ... how much does a cubic foot of water weigh?

- a. 92.8 lbs
b. 56.7 lbs
c. **62.4 lbs**
d. 3.14 lbs

$$8.34 \text{ lbs/gal} \times 7.48 \text{ gal/ft}^3 = 62.4 \text{ lbs/ft}^3$$

7. What is the flow velocity in a 12-inch pipe as compared to the flow velocity in a 24-inch pipe, assuming both pipes are carrying the same volume of water flow.

- a. The same
b. Twice the velocity
c. Three time the velocity
d. **Four time the velocity**

$$\begin{aligned} \text{Cross section of a 12-inch pipe} &= \pi r^2 \\ 3.14 \times (6 \text{ in.} \div 12 \text{ in.})^2 &= 0.785 \text{ ft}^2 \end{aligned}$$

$$\begin{aligned} \text{Cross section of a 24-inch pipe} &= \pi r^2 \\ 3.14 \times (12 \text{ in.} \div 12 \text{ in.})^2 &= 3.14 \text{ ft}^2 \end{aligned}$$

$$3.14 \text{ ft}^2 \div 0.785 \text{ ft}^2 = 4.0$$

8. When pumping water from a well to a treatment process, the Total Dynamic Head is the sum of four (4) components, list these components:
- Friction Head**
 - Suction Head**
 - Static Head**
 - Velocity Head**
9. What is the weight relationship of chlorine liquid as compared to water?
- Water weighs more than liquid chlorine
 - Liquid chlorine weighs 2.5 times more than water
 - Water weighs 1.5 times more than liquid chlorine
 - Liquid chlorine weighs 1.5 times more than water**
10. What will the pressure gauge read on the suction of a pump if the pump is located at floor elevation of the tank and the tank has 30 feet of static water level?
- About 69 psi
 - About 9.5 psi
 - About 13 psi**
 - About 17 psi

*Each foot of water generates 0.433 psi
30 feet of water x 0.433 psi = 12.99 psi*

Please forward your comments and sample questions for publication to:

**Roy Pelletier, Assistant Bureau Chief
City of Orlando Public Works Department
Wastewater Bureau
5100 L.B. McLeod Road
Orlando, Florida 32811**

roy.pelletier@cityoforlando.net (407) 246-2213