



# Certification Boulevard

Roy Pelletier



## Test Your Knowledge of Water Treatment & Other Topics

- A water plant has a ground storage reservoir that is 100 feet in diameter and fills to its maximum operating depth of 25 feet in six hours. Assuming the tank starts empty, what is the average flow rate entering the tank in gpm?
  - A. 416 gpm
  - B. 3,125 gpm
  - C. 4,078 gpm
  - D. 4,546 gpm
- Given the following data, what is the total lbs/day of chlorine consumption in this water plant?
  - Raw water flow rate is 2,550 gpm.
  - Inlet treatment is 3.5 mg/L.
  - Pre-filtration is 1.75 mg/L.
  - Finished water disinfection is 2.75 mg/L.
  - A. 2,245 lbs/day
  - B. 245 lbs/day
  - C. 145 lbs/day
  - D. 1,145 lbs/day
- The finished water product temperature after thermal treatment is 15°C, what is the conversion to °F?
  - A. 59°F
  - B. 68°F
  - C. -5°F
  - D. 72°F
- Given the following data, what is the total daily backwash volume in this water filtration process?
 

*Filter Data:*

  - Hydraulic inflow = 1,500 gpm
  - Operational loading rate = 3 gpm/ft<sup>2</sup>
  - Backwash rate = 25 gpm/ft<sup>2</sup>
  - Backwash cycles per day = 2
  - A. 345,600 gpd backwash
  - B. 3.15% of Q
  - C. 1,800 gpd backwash
  - D. 1.16% of Q
- Which water quality indicator reduces the effectiveness of copper sulfate as an algacide when treating source waters for taste and odor caused by algae?
  - A. Total suspended solids
  - B. Temperature
  - C. Alkalinity
  - D. pH
- What is created when chlorine reacts with total organic carbon?
  - A. Ammonia
  - B. Trihalomethane
  - C. Alkalinity
  - D. Trimethylamine
- Which type of solids is not typically removed with standard water filtration?
  - A. Dissolved
  - B. Suspended
  - C. Settleable
  - D. Total
- Given the following data, and considering a 10% increase in the flow rate and an increased chlorine consumption of 34%, calculate the new lbs/day consumption and dosage of chlorine in this water plant.
 

*Plant Data:*

  - The plant flow rate is 1,388 gpm

- Chlorine consumption is 50 lbs/day
  - A. 55 lbs/day and 3.0 ppm
  - B. 50 lbs/day and 4.0 ppm
  - C. 75 lbs/day and 3.25 ppm
  - D. 67 lbs/day and 3.6 ppm
- Which two chemicals are typically used in a water system chlor-ammonation process?
    - A. Chlorine and Sulfur Dioxide
    - B. Ammonia and Sodium Hydroxide
    - C. Chlorine and Caustic
    - D. Chlorine and Ammonia
  - What is another term for nonvolatile?
    - A. Dissolved
    - B. Soluble
    - C. Organic
    - D. Inorganic

ANSWERS ON PAGE 62

### SEND US YOUR QUESTIONS FOR CERTIFICATION BOULEVARD

Do you have a question or an exercise you would like to feature in "Certification Boulevard?" We'll be glad to publish it. Just send your question (with the answer) or your exercise (with the solution) to:

**Roy A. Pelletier**, Wastewater Consultant  
City of Orlando Public Works Department  
Environmental Services Wastewater Division  
5100 L.B. McLeod Road, Orlando, FL 32811  
roy.pelletier@cityoforlando.net  
Telephone 407-716-2971

There is no limit to the number of questions or exercises you may submit. Please include your name, city, and organization or company so we can give you credit.

# Certification Boulevard Answer Key

From page 37

1. **C. 4,078 gpm**

*Capacity of Tank at Max Level*

$$= \pi r^2 \times \text{depth} \times 7.48 \text{ gal/cu. ft.}$$

$$= 3.14 \times 50 \text{ ft.} \times 50 \text{ ft.} \times 25 \text{ ft.} \times 7.48 \text{ gal/cu. ft.}$$

$$= 1,467,950 \text{ gals}$$

*Total Minutes of Pumping*

$$= 6 \text{ hrs} \times 60 \text{ mins/hr} = 360 \text{ minutes}$$

*Average Flow Rate*

$$= \text{Capacity, gals divided by Minutes Pumped}$$

$$= 1,467,950 \text{ gals divided by 360 minutes}$$

$$= 4,078 \text{ gpm}$$

2. **B. 245 lbs/day**

*Total Flow Treated*

$$= 2,550 \text{ gpm} \times 1,440 \text{ mins/day}$$

$$= 3,672,000 \text{ gpd or } 3.672 \text{ mgd}$$

*Total Chlorine Dosage*

$$= 3.5 \text{ mg/L} + 1.75 \text{ mg/L} + 2.75 \text{ mg/L}$$

$$= 8.0 \text{ mg/L}$$

*Total Lbs/day Consumed*

$$= \text{Flow, mgd} \times \text{Total Dosage, mg/L} \times 8.34 \text{ lbs/gal}$$

$$= 3.672 \text{ mgd} \times 8.0 \text{ mg/L} \times 8.34 \text{ lbs/gal}$$

$$= 245 \text{ lbs/day}$$

3. **A. 59 °F**

$$^{\circ}\text{C} \times 1.8 + 32 = ^{\circ}\text{F}$$

$$15 ^{\circ}\text{C} \times 1.8 + 32 = 59 ^{\circ}\text{F}$$

4. **D. 1.16% of Q**

*Q to filter, gpd*

$$= 1,500 \text{ gpm} \times 1,440 \text{ min/day}$$

$$= 2,160,000 \text{ gpd}$$

*Filter surface area, ft<sup>2</sup>*

$$= 1,500 \text{ gpm} \div 3 \text{ gpm/ft}^2$$

$$= 500 \text{ ft}^2$$

*Filter backwash volume, gpd*

$$= 500 \text{ ft}^2 \times 25 \text{ gpm/ft}^2 \times 2 \text{ cycles per day}$$

$$= 25,000 \text{ gpd}$$

*Filter backwash rate, % of Q*

$$= 25,000 \text{ gpd backwash} \div 2,160,000 \text{ gpd inflow}$$

$$= 0.01157 \times 100 = 1.16\% \text{ of Q}$$

5. **C. Alkalinity**

6. **B. Trihalomethane**

7. **A. Dissolved**

8. **D. 67 lbs/day and 3.6 ppm**

*New plant flow in mgd*

$$= 1,388 \text{ gpm} \times 1.1 \div 694 \text{ gpm/mgd}$$

(Note: 1.1 is the 10% increase in flow)

$$= 2.2 \text{ mgd}$$

*New chlorine consumption*

$$= 50 \text{ lbs/day} \times 1.34$$

(Note: 1.34 is the 34% increase in chlorine)

$$= 67 \text{ lbs/day}$$

*New chlorine dosage*

$$= 67 \text{ lbs/day} \div 2.2 \text{ mgd} \times 8.34 \text{ lbs/gal}$$

$$= 3.6 \text{ ppm}$$

9. **D. Chlorine and Ammonia**

10. **D. Inorganic**