



Certification Boulevard

Roy Pelletier



Test Your Knowledge of Water Treatment and Other Topics

1. A water plant has a ground storage reservoir that is 100 feet in diameter and fills to its maximum operating depth of 25 feet in 6 hours. Assuming the tank starts empty, what is the average flow rate entering the tank in gallons per minutes (gpm)?
A. 416 gpm B. 3,125 gpm
C. 4,078 gpm D. 4,546 gpm
2. Given the following data, what is the total lbs/day of chlorine consumption in this water plant?
• Raw water flow rate is 2,550 gpm.
• Inlet treatment is 3.5 mg/L.
• Pre-filtration is 1.75 mg/L.
• Finished water disinfection is 2.75 mg/L.
A. 2,245 lbs/day B. 245 lbs/day
C. 145 lbs/day D. 1,145 lbs/day
3. The finished water product temperature after thermal treatment is 15 °C; what is the conversion to °F?
A. 59 °F B. 68 °F
C. -5 °F D. 72 °F
4. Which water quality indicator reduces the effectiveness of copper sulfate as an algaecide when treating source waters for

Looking for Answers?

Check the Archives

Are you new to the water and wastewater field? Want to boost your knowledge about topics you'll face each day as a water/wastewater professional?

All past editions of Certification Boulevard through the year 2000 are available on the Florida Water Environment Association's website at www.fwea.org. Click the "Site Map" button on the home page, then scroll down to the Certification Boulevard Archives, located below the Operations Research Committee.

- taste and odor caused by algae?
A. Total suspended solids
B. Temperature
C. Alkalinity
D. pH
5. What should typically happen to filter backwash rates during summer months?
A. They decrease.
B. They stay the same.
C. They increase.
D. They ramp up more slowly.
6. Which type of solids are not typically removed with standard water filtration?
A. Dissolved B. Suspended
C. Settleable D. Total
7. Given the following data, and considering a 10 percent increase in the flow rate and an increased chlorine consumption of 34 percent, calculate the new lbs/day consumption and dosage of chlorine in this water plant.
Plant Data:
• The plant flow rate is 1,388 gpm.
• Chlorine consumption is 50 lbs/day.
A. 55 lbs/day and 3.0 ppm
B. 50 lbs/day and 4.0 ppm
C. 75 lbs/day and 3.25 ppm
D. 67 lbs/day and 3.6 ppm
8. Which two chemicals are typically used in a water system chlor-ammonation process?
A. Chlorine and sulfur dioxide
B. Ammonia and sodium hydroxide
C. Chlorine and caustic
D. Chlorine and ammonia
9. Which of the following is not a by-product of disinfection?
A. Trihalomethanes B. Bromate
C. Haloacetic acids D. Nitrite
10. What is another term for non-volatile?
A. Dissolved B. Soluble
C. Organic D. Inorganic

ANSWERS ON
PAGE 60

SEND US YOUR QUESTIONS

Readers are welcome to submit questions or exercises on water or wastewater treatment plant operations for publication in Certification Boulevard. Send your question (with the answer) or your exercise (with the solution) by e-mail to roy.pelletier@cityoforlando.net, or by mail to:

Roy Pelletier
Wastewater Project Consultant
City of Orlando
Public Works Department
Environmental Services
Wastewater Division
5100 L.B. McLeod Road
Orlando, FL 32811

Certification Boulevard Answer Key

From page 57

1. **C. 4,078 gpm**

Capacity of Tank at Max Level

$$= \pi r^2 \times \text{depth} \times 7.48 \text{ gal/cu. ft.}$$

$$= 3.14 \times 50 \text{ ft.} \times 50 \text{ ft.} \times 25 \text{ ft.} \times 7.48 \text{ gal/cu. ft.}$$

$$= 1,467,950 \text{ gals}$$

Total Minutes of Pumping

$$= 6 \text{ hrs} \times 60 \text{ mins/hr}$$

$$= 360 \text{ minutes}$$

Average Flow Rate

$$= \text{Capacity, gals divided by Minutes Pumped}$$

$$= 1,467,950 \text{ gals divided by 360 minutes}$$

$$= 4,078 \text{ gpm}$$

2. **B. 245 lbs/day**

Total Flow Treated

$$= 2,550 \text{ gpm} \times 1,440 \text{ mins/day}$$

$$= 3,672,000 \text{ gpd or } 3.672 \text{ mgd}$$

Total Chlorine Dosage

$$= 3.5 \text{ mg/L} + 1.75 \text{ mg/L} + 2.75 \text{ mg/L}$$

$$= 8.0 \text{ mg/L}$$

Total Lbs/day Consumed

$$= \text{Flow, mgd} \times \text{Total Dosage, mg/L} \times 8.34 \text{ lbs/gal}$$

$$= 3.672 \text{ mgd} \times 8.0 \text{ mg/L} \times 8.34 \text{ lbs/gal}$$

$$= 245 \text{ lbs/day}$$

3. **A. 59 °F**

$$^{\circ}\text{C} \times 1.8 + 32 = ^{\circ}\text{F}$$

$$15 ^{\circ}\text{C} \times 1.8 + 32 = 59 ^{\circ}\text{F}$$

4. **C. Alkalinity**

5. **C. They increase.**

Warm water is less dense so higher backwash rates are required to achieve the same media bed expansion. Filtration plants should consider adjusting backwash rates seasonally to account for water density.

6. **A. Dissolved**

7. **D. 67 lbs/day and 3.6 ppm**

New plant flow in mgd

$$= 1,388 \text{ gpm} \times 1.1 \div 694 \text{ gpm/mgd}$$

$$(\text{Note: } 1.1 \text{ is the } 10\% \text{ increase in flow})$$

$$= 2.2 \text{ mgd}$$

New chlorine consumption

$$= 50 \text{ lbs/day} \times 1.34$$

$$(\text{Note: } 1.34 \text{ is the } 34\% \text{ increase in chlorine})$$

$$= 67 \text{ lbs/day}$$

New chlorine dosage

$$= 67 \text{ lbs/day} \div 2.2 \text{ mgd} \times 8.34 \text{ lbs/gal}$$

$$= 3.6 \text{ ppm}$$

8. **D. Chlorine and ammonia**

9. **D. Nitrite**

10. **D. Inorganic**